



March 31, 2021

**Addendum 2  
25 & I Road Drainage Improvement Project  
RFP 21-03056**

This addendum to the Request for Proposals (RFP) for the above referenced project supersedes all contrary and conflicting information which is hereby supplemented or revised in certain particulars as follows:

**Question (1):**

What visible issues have occurred due to the failing French drain? Do you know if this is primarily a groundwater issue or a surface water issue?

**Answer (1):**

There is standing water in areas south of I Road that typically does not typically have standing water and the ground surface is saturated. It is assumed the issues are both contributed from ground water and surface water. Mesa County hydrovaced and completed a pipe inspection utilizing a push camera. The video of the pipe revealed excess debris and the pipe is plugged. The original design was completed to address ground water and surface water.

**Question (2):**

Does the major drainage (basin 114) that looks to run through that intersection create drainage problems for the project area (roadway overtopping, etc)? Is the scope limited to addressing the local drainage / groundwater issues along the project extents?

**Answer (2):**

The drainage that you are referring to is northwest of the French drain pipe that will be replaced as part of this project. Although this drainage is an issue, it is not part of this project scope.

**Question (3):**

Are there any roadway improvements proposed for this project?

**Answer (3):**

No, there are no roadway improvements proposed for this project.

**Question (4):**

Wanted to confirm that a site walk is desired at each stage of the project – kick-off, 30%, 60%, 90%?

**Answer (4):**

A site walk through will only be necessary for the kick-off and 90%.

**Question (5):**

How much public involvement has taken place up to this point?


**Answer (5):**

Mesa County has spoken with a few of the neighbors several times regarding the drainage issues. The property owners are aware of the issues, and generally seem content about the project.

This addendum must be acknowledged and included with your RFP submittal.

All remaining requirements of the RFP remain unchanged.

Provided by:

A handwritten signature in black ink that reads "Carrie Gudorf". The signature is written in a cursive style with a large initial 'C'.

Carrie Gudorf  
Mesa County Engineering  
Regulatory Programs Manager